



CERTIFICATE

We, *GE Industrial Solutions group*
acting through its affiliate
GE Industrial Belgium - Nieuwevaart 51 - B-9000 Gent - Belgium

declare that the product/equipment:

<i>Brand:</i>	<i>GE</i>
<i>Product group:</i>	<i>circuit-breaker</i>
<i>Series:</i>	<i>G60, G100, EP60, EP100</i>
<i>Range:</i>	<i>up to 63A</i>

provided that it is installed, maintained and used in the application for which it is made, with respect of the "professional practices", relevant installation standards and manufacturers instructions,

*Comply with IEC & EN 60947-2: 2006 +A12009 and the relevant parts of
IEC & EN 60947-1:2007*

In particular they comply with:

- *Glow wire test according to IEC & EN 60965-2-10 and 60695-2-11*
- *Test flame 50W according to IEC & EN 60695-11-10*

Gent, 19th November 2013

(place and date)

Juan José García Álvarez
Global System Manager

(name, function and signature of the authorized person)