

25/05/2004

CEBEC CERTIFICATION AGREEMENT

Declaration

We, CEBEC srl/cvba, declare that the following products comply with the specified requirement, in order to check the Rated Impuls Withstand Voltage ($U_{imp} = 7,3 \text{ kV}$) of the products according to their relevant standards:

EN 60947-2 Edition 3 2003-04

Product: **Circuit Breaker**

Type: Series G60 & G100

Trade name: GE



Didier LEEMANS
Certification Engineer